



REVISIONS

NO.	DESCRIPTION	DATE	BY

- NOTES**
- CONTROL TRANSFORMERS FOR PUMP STARTERS WITH SEAL WATER SOLENOIDS SHALL HAVE AMPLE CAPACITY FOR SEAL-WATER SOLENOIDS.
 - FLOAT SWITCH LOCATED IN DENASATOR INFLENT SUMP. SUPPLIED BY OWNER. WIRED INTO CONTROL CIRCUIT BY THIS CONTRACTOR.
 - SOLENOIDS VALVES SUPPLIED BY OWNER. OBTAIN VOLT-AMPERE BURDEN FROM VALVE SUPPLIER.
 - FURNISHED BY OWNER.
 - LOCATED IN FILTER CONTROL PANEL



GANNETT FLEMING CORDRY & CARPENTER, INC.
ENGINEERS

600 N. SECOND ST. HARRISBURG, PENNA.

JOB No. 4590	THE PENNSYLVANIA STATE UNIVERSITY CONSTRUCTION OF A MINE DRAINAGE TREATMENT PLANT HUSTON TOWNSHIP, CLEARFIELD CO., PA.	SHEET No. 28
SCALE AS SHOWN		
DATE JUNE 1967	DRAWING No. I-17537	