



100,000 GAL. TANK
 90' TOWER
 2-8" OS+Y. VALVES
 1-8" CHECK VALVE
 1-8x8x3 STD. FLG. TEE
 IN PIT. SEE DETAIL

GROUND LEVEL AT THIS POINT
 13'-0" HIGHER THAN AT BLDG. LINE.

NORTH AMERICAN REFRACTORIES CO.
 CURWENSVILE PLANT
 PROPOSED UNDERGROUND
 WATER MAIN TO SPRINKLER
 SYSTEM.

DATE OCT. 14th 1931. TRACED FROM
 GRINNELL Co. Inc.
 BIP 32 F.P. 119
 DATED 10-5-31.

REMOVE PLUG NOW IN 8" CITY MAIN 80# TO 100# PRESSURE

INDEX 50-1-1082