6-STOP PUSH BUTTONS
AT 320 FT. INTERVALS

MASTER START-STOP
PUSH BUTTON

320 FT.

MASTER CONTROL

2 COND. NO. 14

3 COND. NO. 6

POWER
POWER

1 COND. 4/0
1 COND. 4/0

CONTACTOR CASE

TROLLY

GROUND

ROOM CONV. CONTROL

2 COND. NO. 14

2 FUSED TROLLY TAPS

ROOM CONV.
PUSH BUTT.

SUPPLY TRACK

C.B. JUNCTION BOX

DISTRIBUTION PANELS

MAIN BELT CONV.
STARTER

ONE SIDE
BONDED

LOADING CONV.
STARTER

BELT CONVEYOR

ROOM CONV.
STARTER

MOTOR

ROOM CONV.
STARTER

MOTOR

PROPS SET AT
3 FT. INTERVALS

ROOM CENTERS
78 FT.

BARRIER PILLARS
120 FT.

ROOM WIDTH
14 FT.

TO CUTTING MACHINE

SHAKER CONV.

FRACTURE LINE
36°

SCREW JACKS
AT FACE

ASSEMBLY OF CABLES
FOR CONVEYOR SYSTEM

J.F.C. | DATE NOV. 30-1936