PRESENT STOREHOUSE

INSTALL ANCHOR & GUY.

CUT & REMOVE SOUTHBOUND LINES AT THIS POINT AFTER INSTALLATION OF ANCHOR

REMOVE 35' POLE NOT TO BE REPLACED

PRIVATE CONCRETE ROAD

PRESENT POLE & OVERHEAD WITH CANADIAN PACIFIC LINES

Firewall, Transformer Station

RELOCATE POLE & CONNECTIONS AS SHOWN ON PRESENT POLE LINE

12-500 MCM. W.P. SINGLE COND. LIVERPOOL LINES. 6 TO BE INSTALLED UNDER SURFACE IN PLANKED TRENCH

3 COND. 250 MCM. STEEL ARMORED CABLE.

3 COND. 500 MCM. STEEL ARMORED CABLE

3 COND. 500 MCM. STEEL ARMORED CABLE NOT IN SERVICE.

PLAN

PRESENT & FINAL CABLE LOCATION

REMOVE POLE GUY WIRE & RELOCATE

PRESENT ANCHOR

CUT & REMOVE NORTHBOUND LINES AT THIS POINT AFTER INSTALLATION OF ANCHOR. 3-NO 6 1 3-NO 8 AL. 4-NO 6 SD. NO 8. NOT TO BE REPLACED.

TILT POLE STRUTTED PER DWG. ED-389

33'-6"

PLAN TEMPORARY CABLE LOCATION

SEE DWG 301 FOR CABLE SUPPORTS

PRESENT LOCATION OF ARMORED CABLES

PLANK OVER FOR CABLE PROTECTION

TEMPORARY LOCATION OF ARMORED CABLES DURING CONSTRUCTION

ELEV. 1013.6

DITCH GROUND TO DRAIN WATER FROM TEMPORARY CABLE TRENCH

ELEVATION

LOOKING NORTH

SEE MATERIAL LIST ED-390

THE LEHIGH COAL & NAVIGATION CO.
LANSFORD, PA.

INSTALLATION ELECTRICAL PREPARATION OF SITE FOR DEEP WELL PUMPS

Location: TAMAQUA MINE

Scale: 1/8" = 1'-0"
DWG BY: H.E.B.
Date: 11-5-52

ED-360