

Continue 3 - #6 Bare Copper Wires  
150 Ft. to Existing Pole With 100KV  
3 Phase 25 Cycle Power. L.O. & M. Co.  
To Fasten and Connect to Existing Pole.



Note: Use #6 Ground Wire Under  
Bolt and Staple to Pole Base  
Setting Pole

ELEVATION - FRONT VIEW  
Looking North

Approx. Ground Level of Poles - Elev. 1615'

Project I - Dec. 21, 1928 To Connect Existing Transmission To New Side of Pole Top Switch	THE LEHIGH COAL & NAVIGATION CO. LANCASTER, PA.
	Description: Two Pole Structure Construction Drawing for Deep Well Poles
	Location: TAMBOUR MINE
	Scale: 1/2" = 1'-0" Design: H.E.B.
	ED359