PRESENT STOREHOUSE

INSTALL ANCHOR & GUY.

CUT & REMOVE SOUTHBOUND LINES AT THIS POINT AFTER INSTALLATION OF ANCHOR

REMOVE 35' POLE NOT TO BE REPLACED

PRIVATE CONCRETE ROAD

CUT & REMOVE NORTHBOUND LINES AT THIS POINT AFTER INSTALLATION OF ANCHOR

PRESENT TRANSFORMER STATION

12-500 MCM. W.P. SINGLE COND. OVERHEAD LINES. TO BE INSTALLED UNDER SURFACE IN PLANKED TRENCH.

PLAN
PRESENT & TEMP. CABLE LOCATION

3 COND. 250 MCM. STEEL ARMORED CABLE.

3 CONDUCTOR MCM. STEEL ARMORED CABLE.

3 COND. 300 MCM. STEEL ARMORED CABLE. NOT IN SERVICE.

TWO-POLE STRUCTURE
DET. DWG. ED-359

REMOVE POLE GUY WIRE & RELOCATE

PRESENT ANCHOR

CUT & REMOVE NORTHBOUND LINES AT THIS POINT AFTER INSTALLATION OF ANCHOR. 3-NO 2/0, 3 NO. #10 4-NO 6 12 NO #8 NOT TO BE REPLACED

SEE DWG. 3.01 FOR CABLE SUPPORTS

PLAN TEMPORARY CABLE LOCATION

PRESENT LOCATION OF ARMORED CABLES

PLANK OVER FOR CABLE PROTECTION.

TEMPORARY LOCATION OF ARMORED CABLES DURING CONSTRUCTION

ELEV. 1012.6

DITCH GROUND TO DRAIN WATER FROM TEMPORARY CABLE TRENCH

ELEVATION
LOOKING NORTH

SEE MATERIAL LIST FOR 3-500 M...

THE LEHIGH COAL & NAVIGATION CO.
LANSFORD, PA.

Description: ELECTRICAL PREPARATION OF SITE FOR DEEP WELL PUMPS.

Location: TAMAQUA MINE.

Scale: 1/8" = 1'-0"
DWG BY: M.E.P.
Date: 7-8-60

ED-360