



NOTE:
6" SCH 40 PIPE SHOULD BE WELDED TO 1/2" AND THREADED BOTH ENDS - 6" OUTSIDE EXTENSION AND 1/2" LONG 6" 1/2 HALF ROUND SECTION SHOULD HAVE 1/2" FLANGERS WELDED TO PIPE TO CONNECTION TO HALF ROUND TROUGH

NOTE:
NOT TO BE USED FOR CONSTRUCTION UNTIL VENDOR'S PRINTS ARE APPROVED

NO.	REVISIONS	DATE
11	7-17-77 ADDED INTERNAL CONNECTOR	(F.D.S.)
10	5-12-77 SWITCHED PUMP NUMBERS 1 & 2	(W.A.W.)
9	4-6-77 MOVED FOOTING AND CHANGED LIME STORAGE BIN	(F.D.S.)
8	3-17-77 CHANGED DETAIL C PER SHOP DWG.	(E.O.S.)
7	2-17-77 ADDED DUST COLLECTOR	
6	2-17-77 RELOCATED LIME SLAKER & FEEDER & LIME SLURRY PUMP	
5	2-17-77 EXPANDED DETAIL D TO SHOW 2" PIPE THROUGH WALL & CONNECTION TO TROUGH	
4	2-17-77 ADDED DETAIL X	
3	2-17-77 ADDED DETAIL Y	
2	2-17-77 CHANGED SLURRY TANK FOOTING	
1	2-17-77 PROVIDE MECHANICAL JOINTS. - (SEE DWG C-12-REVISION 2)	

CHEMICAL FEED SYSTEM
 CONSTRUCTION OF TREATMENT FACILITIES FOR ACID MINE DRAINAGE
 RAUSCH CREEK WATERSHED
 SCHUYLKILL COUNTY, PENNSYLVANIA

ANTHACITE RESEARCH & DEVELOPMENT CO. INC.
 CONSULTING ENGINEERS
 POTTSVILLE, PENNSYLVANIA

JOB NO. 6858
 DATE: JAN 1970
 SCALE: AS NOTED
 DRAWN: RGS
 APPROVED: J.R. J. J. J.

DRAWING NO. **C-33**