



INSULATORS	DIMENSIONS IN INCHES								WORKING VOLTAGE	STD. PKG
	A	B	C	D	E	F	G	H		
OHIO BRASS CO #26823	$\frac{3}{4}$	$4\frac{1}{2}$	7	$2\frac{1}{4}$	$4\frac{3}{4}$	$3\frac{1}{2}$	$7\frac{1}{2}$	$10\frac{1}{2}$	45,000	6
OHIO BRASS CO. #26822	$\frac{3}{4}$	$4\frac{1}{2}$	$6\frac{3}{8}$	$2\frac{1}{4}$	4	$3\frac{1}{8}$	7	9	35,000	6
LOCKE INSULATOR CO. #1035 G 2	1	$4\frac{3}{4}$	$6\frac{1}{4}$	$2\frac{1}{8}$	4		7	9	35,000	6
WEST. ELECT. & MFG. CO. # 2122	$1\frac{1}{4}$	$4\frac{1}{4}$	$6\frac{1}{4}$	2	$4\frac{1}{2}$	$3\frac{1}{2}$	7	9	35,000	6
R. THOMAS & SONS CO. # 2125	$\frac{7}{8}$	$4\frac{1}{2}$	$6\frac{1}{4}$	2	4	$3\frac{3}{8}$	7	9	35,000	12

BROWN PORCELAIN PIN INSULATORS

NOTE: THIMBLE FOR $\frac{3}{4}$ " DIA. 10-THDS TO INCH TO BE

FURNISHED WITH AND CEMENTED IN INSULATOR

⊕ USE ON STEEL STRUCTURE

New Insulator 6/20/58

Line Material #NP273

SAME NOTE AS TO $\frac{3}{4}$ " THIMBLE APPLIES

PIN INSULATORS - 22 KV.

ENGINEERING DEPARTMENT
SUSQUEHANNA COLLIERIES COMPANY
LYTLE COAL COMPANY

Wilkes Barre PA 2-24-1929 SCALE $\frac{1}{2}$ SIZE

DRAWN BY Dougher

CHECKED BY

APPROVED CAM

DR. NO. 66-531

OK 8/17/51