



- POTENTIAL**
- CONDUCTORS
  - TIES - TYPE
  - INSULATORS
  - PINS
  - CROSS ARMS
  - " " BOLTS
  - " " BRACES
- POLE BEACE BOLT**
- SPACERS
- POLE**
- GUYS
  - ANCHOR RODS
  - ANCHORS
  - BAYONETS
  - GROUND
  - CLAMPS
- SPECIFICATIONS**
- 6600 Volt
  - 3 1/2 H.D. Str. B. Copper
  - No. 4 Copper
  - Straight-Line OB 34622
  - 3/8 Galv. Steel Lead Dip OB 71410
  - 4" x 5" x 3" 0"
  - 3/4" x 18" Galv.
  - Joist Wood 2" x 2" x 3" 0" Creosote
  - 1/2" x 3/4" Lag Screws
  - 3/4" x 18" Long with 4 nuts and 4 Washers.
  - Red Wood Cedar-Class 2
  - 3/4" Galv. Steel
  - 1/2" x 6" 0" U 7426
  - Old Mripe Car Wheel
  - 3" x 3" x 6" Long Galv. J1725.
  - No. 4 HD Str. B. Copper
  - Joistlin

ROCHESTER & PITTSBURGH COAL CO.  
 PLAN AND PROFILE  
 OF  
 PROPOSED TRANSMISSION LINE CROSSING  
 B. & O. R.R. - INDIANA BR.  
 WHITE TWP. - AT STATION 1856+00. - INDIANA CO.  
 SCALE: AS SHOWN MAY 1949.